

SCHEDULE –H
(See Clause 14.1.2)

TESTS

1 Schedule for Tests

- 1.1 The Concessionaire shall, not later than 30 (thirty) days prior to the likely completion of System Upgradation, notify the Independent Engineer and the Authority of its intent to subject the Water Supply and Sewerage System to Tests, and not later than 7 (seven) days prior to the actual date of Tests, furnish to the Independent Engineer and the Authority detailed inventory and particulars of all works and equipment forming part of System Upgradation.
- 1.2 The Concessionaire shall notify the Independent Engineer of its readiness to subject the Water Supply and Sewerage System to Tests at any time after 7 (seven) days from the date of such notice, and upon receipt of such notice, the Independent Engineer shall, in consultation with the Concessionaire, determine the date and time for each Test and notify the same to the Authority who may designate its representative to witness the Tests. The Independent Engineer shall thereupon conduct the Tests itself or cause any of the Tests to be conducted in accordance with Article 14 and this Schedule-H.

2 Tests

- 2.1 Visual and physical Test: The Independent Engineer shall conduct a visual and physical check of the Water Supply and Sewerage System to determine that all works and equipment forming part thereof conform to the provisions of this Agreement.
- 2.2 Test run: The Independent Engineer shall undertake a test run of the Project Water Supply and Sewerage System to determine that the quality of service conforms to the provisions of the Agreement.
- 2.3 Other Tests: The Independent Engineer may require the Concessionaire to carry out or cause to be carried additional Tests, in accordance with Good Industry Practice, for determining the compliance of the Water Supply and Sewerage System with Specifications and Standards.
- 2.8 Environmental audit: The Independent Engineer shall carry out a check to determine conformity of the Water Supply and Sewerage System with the environmental requirements set forth in Applicable Laws and Applicable Permits.
- 2.9 Safety review: Safety audit of the Water Supply and Sewerage System shall have been undertaken by the Safety Consultant as set forth in Schedule-K, and on the basis of such audit, the Independent Engineer shall determine conformity of the Water Supply and Sewerage System with the provisions of this Agreement.

3 Agency for conducting Tests

All Tests set forth in this Schedule-H shall be conducted by the Independent

Engineer or such other agency or person as it may specify in consultation with the Authority.

4 Completion/Provisional Certificate

Upon successful completion of Tests, the Independent Engineer shall issue the Completion Certificate or the Provisional Certificate, as the case may be, in accordance with the provisions of Article 14.